



# ENERG

енергия · ενεργεια

Y IJA  
IE IA



Model Outdoor unit **MXZ-2HA40VF**  
Indoor unit1/2 **MSZ-HR25/25VF**

SEER

**A<sup>++</sup>**

kW **4,0**  
SEER **8,12**  
kWh/annum **172**

SCOP

**A<sup>+</sup>**

kW	X	<b>3,2</b>	X
SCOP	X	<b>4,30</b>	X
kWh/annum	X	<b>1043</b>	X

Indoor unit1/2 **57dB**

Outdoor unit **59dB**



ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI  
626/2011





PRODUCT INFORMATION (*1)			
ROOM AIR CONDITIONER		INDOOR MODEL 1/2/3 INDOOR MODEL 4/5/6 OUTDOOR MODEL	MSZ-HR25VF / MSZ-HR25VF / - - / - / - MXZ-2HA40VF
Function (indicate if present)		If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.	
cooling	Y	Average (mandatory)	Y
heating	Y	Warmer (if designated)	N
		Colder (if designated)	N
Item	symbol	value	unit
Design load			
cooling	Pdesignc	4,0	kW
heating/Average	Pdesignh	3,2	kW
heating/Warmer	Pdesignh	x	kW
heating/Colder	Pdesignh	x	kW
Declared capacity for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
Tj=35°C	Pdc	4,00	kW
Tj=30°C	Pdc	3,00	kW
Tj=25°C	Pdc	1,90	kW
Tj=20°C	Pdc	1,85	kW
Declared capacity for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	2,90	kW
Tj=2°C	Pdh	1,90	kW
Tj=7°C	Pdh	1,11	kW
Tj=12°C	Pdh	1,40	kW
Tj=bivalent temperature	Pdh	2,90	kW
Tj=operating limit	Pdh	2,10	kW
Declared capacity for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	Pdh	x	kW
Tj=7°C	Pdh	x	kW
Tj=12°C	Pdh	x	kW
Tj=bivalent temperature	Pdh	x	kW
Tj=operating limit	Pdh	x	kW
Declared capacity for heating/Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	x	kW
Tj=2°C	Pdh	x	kW
Tj=7°C	Pdh	x	kW
Tj=12°C	Pdh	x	kW
Tj=bivalent temperature	Pdh	x	kW
Tj=operating limit	Pdh	x	kW
Tj=-15°C	Pdh	x	kW
Bivalent temperature			
heating/Average	Tbiv	-7	°C
heating/Warmer	Tbiv	x	°C
heating/Colder	Tbiv	x	°C
Cycling interval capacity			
for cooling	Pcycc	x	kW
for heating	Pcyh	x	kW
Degradation co-efficient	Cdc	0,25	-
Electric power input in power modes other than 'active mode'			
off mode	POFF	4	W
standby mode	PSB	4	W
thermostat - off mode	PTO	7	W
crankcase heater mode	PCK	0	W
Capacity control (indicate one of three options)			
fixed		N	
staged		N	
variable		Y	
Contact details for obtaining more information		MITSUBISHI ELECTRIC CORPORATION SHIZUOKA WORKS 3-18-1, Oshika, Suruga-ku, Shizuoka 422-8528, Japan E-mail: melshierp@nb.MitsubishiElectric.co.jp	

(\*1) This information is based on the "product information requirement" in COMMISSION REGULATION (EU) No206/2012,

(\*2) This GWP value is based on Regulation (EU) No.517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No.626/2011, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.

**TECHNICAL DOCUMENTATION (1)**

ROOM AIR CONDITIONER	INDOOR MODEL 1	MSZ-HR25VF	280H838W228D (mm)
	INDOOR MODEL 2	MSZ-HR25VF	280H838W228D (mm)
	INDOOR MODEL 3	-	-
	INDOOR MODEL 4	-	-
	INDOOR MODEL 5	-	-
	INDOOR MODEL 6	-	-
	OUTDOOR MODEL	MXZ-2HA40VF	550H800W285D (mm)

Function	
cooling	Y
heating	Y

The heating season	
Average (mandatory)	Y
Warmer (if designated)	N
Colder (if designated)	N

Capacity control	
fixed	N
staged	N
variable	Y

Item	symbol	value	unit
Seasonal efficiency (2)			
cooling	SEER	8,12	-
heating/Average	SCOP/A	4,30	-
heating/Warmer	SCOP/W	x	-
heating/Colder	SCOP/C	x	-

Energy efficiency class			
cooling	SEER	A++	-
heating/Average	SCOP/A	A+	-
heating/Warmer	SCOP/W	x	-
heating/Colder	SCOP/C	x	-

Other items			
Sound power level (indoor1,2/outdoor)	LWA	57,57/59	dB(A)
Refrigerant	-	R32	-
Global warming potential	GWP (3)	675	kgCO <sub>2</sub> eq.

identification and signature of the person empowered to bind the supplier	
	Tadashi Saito Department Manager, Quality Assurance Department MITSUBISHI ELECTRIC CONSUMER PRODUCTS(THAILAND) CO.,LTD

(1) This information is based on COMMISSION DELEGATED REGULATION (EU)No626/2011,

(2) SEER/SCOP values are measured based on FprEN 14825:2016: Testing and rating at part load conditions and calculation of seasonal performance

(3) This GWP value is based on Regulation (EU) No.517/2014 from IPCC 4th Assessment Report.

For Regulation (EU) No.626/2011, which cites the IPCC Third Assessment Report, Climate Change 2001, the GWP is 550.