Required information for RVU in COMMISSION REGULATION (EU) No. 1254/2014 ANNEX IV

(a)	Supplier's name	MITSUBISHI ELECTRIC CORPORATION
(b)	Model name	LGH-15RVX-E (LGH-15RVX-E-1)
(c)	SEC (kWh/(m2.a))	Average : -40.1 Cold : -77.3 Warm : -16.2
(d)	Declared typology	RVU,BVU
(e)	Type of drive	Multi-speed
(f)	Type of HRS	Recuperative
(g)	Thermal efficiency (%)	78.3
(h)	Maximum flow rate (m3/h)	137
(i)	Electric power input (kW)	0.05
(j)	Casing sound power level (dB)	41
(k)	Reference flow rate (m3/s)	0.03
(I)	Reference pressure difference (Pa)	54
(m)	SPI (W/(m3/h))	0.24
(n)	Control factor and typology	Local demand control
(o)	Maximum leakage rate (%)	10
(p)	Mixing rate of non-ducted	-
(q)	Visual filter warning	Filter maintenance sign is displayed on the dedicated remote controller. Refer to the Maintenance section in the instruction manual.
(r)	Instructions to install regulated supply/exhaust grilles for unidirectional ventilation	-
(s)	Internet address for disassembly instructions	http://erp.mitsubishielectric.eu/
(t)	Airflow sensitivity for non-ducted units	-
(u)	air tightness for non-ducted units	-
(v)	AEC (kWh/a)	Average: 2.03 Cold: 7.40 Warm:1.58
(w)	AHS (kWh primary energy/a)	Average 44.5 Cold 87.1 Warm 20.1

MITSUBISHI ELECTRIC CORPORATION


Manufactured by: MITSUBISHI ELECTRIC CORPORATION

TOKYO BLDG., 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN

Importer in EU: MITSUBISHI ELECTRIC EUROPE B.V.

HARMAN HOUSE, 1 GEORGE STREET, UXBRIDGE, MIDDLESEX, UB8 1QQ, U.K.

Revise A: 01/April/2021



N15HHGT0035A