

Required information for RVU in  
COMMISSION REGULATION (EU) No. 1254/2014 ANNEX IV

|     |   |  |
|-----|---|--|
| (a) | Supplier's name   | MITSUBISHI ELECTRIC  |
| (b) | Model name  | VL-350CZPVU2-L-EG  |
| (c) | SEC(kWh/(m2.a))   | Cold region : -81.1  |
|     |   | Average region : -42.1   |
|     |   | Warm region : -17.2  |
| (d) | Declared typology   | RVU,BVU  |
| (e) | Type of drive   | VARIABLE_SPEED_DRIVE   |
| (f) | Type of HRS   | Recuperative   |
| (g) | Thermal efficiency (%)  | 87.5   |
| (h) | Maximum flow rate (m3/h)  | 350  |
| (i) | Electric power input (W)  | 176  |
| (j) | Casing sound power level (dB)   | 51   |
| (k) | Reference flow rate (m3/s)  | 0.07   |
| (l) | Reference pressure difference (Pa)  | 50   |
| (m) | SPI (W/(m3/h))  | 0.29   |
| (n) | Control factor and typology   | Local demand control   |
| (o) | Maximum leakage rate (%)  | 7%   |
| (p) | Mixing rate of non-ducted   | -  |
| (q) | Visual filter warning   | Filter maintenance sign is displayed on the dedicated remote controller. Refer to the Maintenance section in the instruction book. |
| (r) | Instructions to install regulated supply/exhaust grilles for unidirectional ventilation | -  |
| (s) | Internet address for disassembly instructions   | <a href="http://erp.mitsubishielectric.eu">http://erp.mitsubishielectric.eu</a>  |
| (t) | Airflow sensitivity for non-ducted units  | -  |
| (u) | air tightness for non-ducted units  | -  |
| (v) | AEC (kWh/a)   | Average region : 2.0   |
| (w) | AHS (kWh primary energy/a)  | Cold region : 90.8   |
|     |   | Average region : 46.4  |
|     |   | Warm region : 21.0   |

## MITSUBISHI ELECTRIC CORPORATION

Manufactured by: MITSUBISHI ELECTRIC CORPORATION  
TOKYO BLDG., 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN

